

ABU DHABI COMMERCIAL ENGINEERING SERVICES

REQUEST FOR APPROVAL OF SPECIFIED MATERIALS

Project Name:	Commercial Building for Mr. Ahmed Rashed Al Murar	File No.	ADCE 923
Location:	Sector E-11, Plot C-23, Abu Dhabi, UAE	Ref No.	923-HCM-AR-MAR-0006
Consultant:	Heberger Engineering Consultancy	Rev. No.	00
Contractor:	Hashim Contracting & Gen. Maintenance Co. LLC	Date	01-Sep-23

☐ S:Structural

☒ A:Architectural

☐ E:Electromechanical

☐ O:Others

Item Description : ECOFAIR FC-2 (Single Component Polymer Modified Cementitious Pinhole Filler)

List of Supplier/ Manufacturer as per specification

N/A

References (pages and item numbers) in:

- 1- BOQ -
- 2- Particular Specs.
- 3- General Specs.
- 4- Drawings



Submitted Material Details

Supplier/ Manufacturer Name: Envirocon

Catalogue No.

Brand Name: ECOFAIR FC-2

Reference pages in the catalogue:

Applicator name: Hashim Contracting

Model/ Article Nos.

Remarks: not in vendor list

Originator of the submittal :

Eng. Samer Ataallah Al Ali


Mob. No. 055-9966852

Contractor Authorizes signature:


Date:

The Contractor Statement: We certify that the materials submitted herewith has been reviewed in details and in compliance with the contract drawing and specifications stated hereabove.

Consultant Comment



Please refer comments on the attached comments sheet



☐ A: Approved

☒ B: Approved as noted

☐ C: Revise & Resubmit

☐ D: Not Approved

Reviewer of the submittal:

Mob. No.

Consultant Authorizes signature:

Date:

06.09.2023

Approval or Comments does not relieve the contractor from his contractual obligations & responsibilities

ADCE (Abu Dhabi Commercial Engineering) Received

☐ A: Approved

☐ B: Approved as noted

☐ C: Revise & Resubmit

☐ D: Not Approved

Date: _____

All the supportive documents must be presented and filed at project site.
The Alternative materials should be submitted to ADCE for review with all the supportive documents, Original catalogues and compliance chart.



COMMENTS SHEET

PROJECT: Commercial Building for Mr. Ahmed Rashed Al Murar, Sector E-11, Plot C-23, Abu Dhabi, UAE			
Consultant: 	Client: 	Main Contractor: 	
MATERIAL SUBMITTAL		File No. ADCE 923	
		Transmittal Ref: 923-HCM-AR-MAR-0006	
		Rev No. 00	
		Date: 01-Sep-2023	
Subject:			
☐ A. No Objection ☒ B. No Objection Subject to incorporation of all comments as noted ☐ C. Rejected to be resubmitted ☐ D. Rejected			
No Objection with repair material ECOFAIR FC2, subjected to comply fully with the manufacturer's recommendation, project specs and MS.			
The contractor must not use the material for structural repair unless review and approved by us for the required repair.			
			
Consultant Confirmation :		Date:	06.09.2023