



**RUWAIS HOUSING COMPLEX EXPANSION – PHASE IV
CONSTRUCTION OF BUILDINGS ACCOMMODATIONS – PACKAGE 4**
PROJECT No. 7010C6
AGREEMENT No. 147010C6



MATERIAL APPROVAL REQUEST (MAR)

Serial No. **C 0 3 3 7**

Rev. No. **0 0**

Date **2 8 1 0 1 5**

S/C Ref.

Material Description : **Eco Grout GP - Envirocon**

Trade Name

Eco Grout GP

Manufacturer

M/s. Ecovirocon

Supplier

M/s. Ecovirocon Construction

ADNOC Reg. No.

907390

Specification
requirement detail


Technical Specification: **N/A**

Location / Area
of use

For Horizontal and Vertical Grouting of the Precast elements

Technical
detail

As Per Attachment



Discipline:

Civil

Attachments:

1 Specification comparison Sheet

☒ Yes

☐ NA

4 Other supporting documents (list)

2 Samples

☐ Yes

☒ NA

3 Original Brochure

☒ Yes

☐ NA

As per Index

As per attached Pre-Qualification Copy

NA :- Not applicable

Notes/Comments:-

For CONTR.

☐ Accepted

☐ Accepted
subject to

☐ Incorporate comments,
resubmit before proceeding

☐ Not accepted

Comments:

Name : **Engr. Zahir Al Rasasy**

Date: **28-Oct-15**

Signature:

For ADNOC

☐ Accepted

☒ Accepted
subject to

☐ Incorporate comments,
resubmit before proceeding

☐ Not accepted


Comments:

- Subjected to ITL test result from site sample -
- Final approval is subjected to mock-up.
- Grouting material shall be used up to C50.

Name: **Engr. Vijayan Jayaraman**

Date:

Signature:



MED	SR. QA/A	SPE	SR. CONT.	SR. HSE	CM	CS	CR C/S ENG.	SR. ARCH	SR. MECH	SR. ELEC	SPE	HSE	OTHER