


CLIENT  شركة أبوظبي للتوزيع Abu Dhabi Distribution Company		CONSULTANT  مكتب الدكتور محمود علي الساعي للاستشارات الهندسية والتصاميم Dr. Mahmood Ali Al Sai Engineering Consultancy & Design Bureau		CONTRACTOR 		
Contract No. D-110489 Water Supply to Al Yaasat Al Sufla Island in Al Dhafra Region.				Date	18 th July 2023	
				COMMENT SHEET NO. IM-WT/074		
Contractor Ref.	TGC/P/D-110489/103/23			To	Tasneem Gen. Contracting Co. & Real Estate Management. L.L.C.	
Doc. No	TGC/D-110489/MS/33			Attn	Eng. Yousef Tayem General Manager.	
Dated:	13/07/2023	Received on:	13/07/2023			
CLIENT'S/CONSULTANT'S COMMENTS						
Title					Rev.	Status
MAS 33 for Concrete Repairing / Finishing. Material Manufactured by M/s Envirocon Construction Products L.L.C, UAE.					00	2
1. Reference: Contractor submittal ref. No. TGC/P/D-110489/103/23 dated 13/07/2023. 2. Status: The Contractor submitted MAS 33 for Concrete Repairing / Finishing, Manufactured by M/s Envirocon Construction Products L.L.C, UAE is "Approved Except as Noted". 3. Engineer's Comments: 3.1. No any repair works to be permitted at site without a prior inspection and approval by the consultant 3.2. Manufacturer's recommendations to be followed precisely at site. 3.3. The material shall be used in spaces up to maximum of 100mm thickness as per manufacturer's recommendations. In case of any areas exceeded that thickness, no aggregate are allowed to be added at site and a different material to be proposed to match with the required thickness of repair at site.						
1	Approved	2	<u>Approved Except as Noted</u>			
3	Not Approved-Resubmit	4	For Information – Approval Not Required			
5	Additional Information is Required. Document to be Resubmitted					

ENGINEER	
SIGNATURE:	 
DATE: ...	18/07/2023
	