

Project Name: LIV Marina Tower - 2

Subtl. #: LIV2-CRCC-MT-ST-0035.

Rev. : 01

TO : NORR Architects and Engineers

P.O. Box 13213, Dubai, U.A.E

FROM : China Railway 18th Bureau Group LLC

Contract Title : LIV Marina Tower - 2 (Main Works)

Date Submitted : 30-Apr-2023

Time : 9:01 AM

Specification / BOQ Ref. :

Location of use : Zone : Level: Projectwide Gridline :

ENCLOSURES :

ISSUED FOR :

- ☒ Technical Data
- ☐ Samples
- ☒ Compliance Statement
- ☒ Method Statement
- ☒ Test Reports
- ☐ Calculations
- ☐ Warranty
- ☐ Shop Drawing
- ☐ O&M Manual (Prel.)
- ☐ O&M Manual (Final)
- ☐ Preliminary As-Built
- ☐ Final As-Built
- ☐ Schedule
- ☒ Others

- ☒ Issued For Approval
- ☐ Issued For Information / Records

DESCRIPTION :

MATERIAL SUBMITTAL FOR HIGH FLOW NON-SHRINK GENERAL PURPOSES
CEMENTITIOUS GROUT (ALTERNATE SUPPLIER)

MANUFACTURER :

SUPPLIER :

ENVIROCON CONSTRUCTION PRODUCTS
FACTORY LLC

ENVIROCON CONSTRUCTION PRODUCTS
FACTORY LLC

Only One Item per Submittal is recommended

CONFIRMATION OF CONTRACTOR'S Q.C. DEPARTMENT

Confirmation of Co-ordination & compliance with Specifications, Contract drawings, Method Statements and QAQC Plan.

Tick Box ☒ YES ☐ NO

Note: If NO, any departure from Specifications, approved drawings, Method Statement and Quality Control Plan to be recorded and attached.

Contractor :

Date : 30-Apr-2023

ENGINEERS COMMENTS :

ISSUE / RECEIVE STAMPS

Conditional approval subject to the following conditions:

- Grouting material shall be use for filling gaps of MEP sleeves ONLY.
- Contractor shall submit a brief Method Statement of high flow non shrink grout (pre-mix pack); surface preparation, mixing, application curing, etc. for the engineer's review and approval
- Contractor shall submit grout compressive strength test report result at 7 and 28 days for the engineer's review and approval.
- Contractor shall submit MIR (Material Inspection Request) in every high flow non shrink grout (pre-mix pack) delivery at site

For and on behalf of The Engineer:

Date: 10 May 2023

STATUS :

The Engineers comments shall not relieve the Contractor of any of his responsibilities under the Contract.

- ☐ A - Reviewed
- ☒ B - Reviewed as Noted
- ☐ C - Revise & Resubmit
- ☐ R - Not Reviewed

Received for Contractor :