

MATERIAL APPROVAL SUBMITTAL SHEET		MASS No.: N-17723-0082
		PREVIOUS No.: N-17723-0059
CSD No. N-17723-HK-5100-H-4512 Rev.B		
CONTRACT No.	:	N-17723
CONTRACT TITLE	:	Supply and Installation of New +300/-300 MVar 132kV DRPC (STATCOM) at 400/132kV Capital Grid Station
LOCATION	:	MAHAWI
APPROVAL REQUEST FOR - MATERIAL DESCRIPTION		MATERIAL IDENTIFICATION CODE:
MATERIAL SUBMITTAL FOR NON-SHRINK CEMENTITIOUS GROUT (Eco-Grout GP)		Not Applicable
		☒ ORIGINAL CATALOGUE ENCLOSED
		☐ SAMPLE ENCLOSED Not Applicable
MANUFACTURER:		COUNTRY OF MANUFACTURER:
M/s. Envirocon Construction Products Factory LLC		UAE
LOCAL SUPPLIER		VENDOR LIST REFERENCE:
M/s. Envirocon Construction Products Factory LLC		9925126
☒		The proposed vendor is in the approved vendor list of ADWEA (TAQA)
FUTURE INFORMATION AND COMMENTS:		
DEVIATIONS FROM SPECIFICATIONS:		
<i>Contractor and its sub-contractor undertake that the work will be done as per specifications and manufacturer's instruction and we understand that this approval does not relieve us of our responsibilities for any discrepancies, errors, mistakes, omissions of deficiencies in the document or material.</i>		
ON BEHALF OF CONTRACTOR	ON BEHALF OF ENGINEER	ON BEHALF OF EMPLOYER
  Philip Horlemann Project Manager	 	
Hitachi Energy Systems LLC	ENERGO CONSULT LLC.	PROJECT EXECUTIVE TEAM
Date: 14.10.2023	Date: 27-10-2023	Date:

P.O. Box 173, Abu Dhabi, UAE
Tel: +971 2 4164000
Fax: +971 2 4164441

Hitachi Energy System LLC
Tel: +971 2 493 8000
Fax: +971 2 557 0145

P.O. Box 52473, Abu Dhabi, UAE
Tel: +971 2 676 3554
Fax: +971 2 676 3559

CONTRACT NO. N-17723

Supply and Installation of New +300/-300 MVar 132kV DRPC (STATCOM) at 400/132/33kV Capital Grid Station

Document Comments Sheet

MASS Ref. No.	No. of Page	Receiving Date	Review days
MASS 0082	2	16 th Oct. 2023	10

Categories for Approval – Status

Approved	: AP
Approved Except as Noted	: AEN
Not Approved	: NA
Not Subject to Approval	: NSA
Returned	: RT

Item No.	Drawing/Document CSD No.	Drawing/Document Title	Rev.	Approval Status
1.	N-17723-HK-5100-H-4512	Material Submittal for Nonn-Shrink Cementitious Grout	B	AP

Following details/comments shall be incorporated:

1. Material is suitable for use for pile head grouting.
2. No objection to use in contact with PVC waterproofing membrane as per AMC PROTECTION confirmation.

TRANSCO COMMENTS: