

 ROYAL DEVELOPMENT COMPANY AN ESG COMPANY  RAPM ARCHITECT PROJECT MANAGEMENT AN ESG COMPANY  nsvscvc nscc International			
PROJECT : Construction of Enabling Works - Phase 2 of Reem Hills Development on Plot TMP2, Sector RT7, Al Reem Island, Abu Dhabi, UAE			
EMPLOYER	Reem Hills Sole Proprietorship LLC		
Employer Project Manager	Royal Development Company		
Employer Project Manager	RAPM Architect Project Management		
ENGINEER	AECOM Middle East LLC		
CONTRACTOR	M/s. NSCC International Limited		
From :	Name : Mohamed Zayed	Position: Project Director / Project Manager	Company: NSCC International Limited
To :	Name : Ibrahim Saidi	Position : Resident Engineer (RE)	Company: AECOM
cc1:	Name: Rami Hani Sahawneh	Position: Project Manager	Company: RAPM
	Name :Azem Al-Kurdi	Position : Project Manager	Company:RDC
	Name : Tan Choon Wiew	Position : Project Director	Company: Q - Properties
MATERIAL SUBMITTAL			
☒ NEW SUBMITTAL		REFERENCE:	RHP2P1-EW-NSC-XX-00-MT-ST-00017[00]
☐ RESUBMITTAL		DATE:	04 May 2024
B.O.Q. Ref. No.	N/A		
Description	Material Submittal for ECOGROUT PHT (Supplier - Envirocon)		
Specification Clause Ref.	316327-3349 Rev.00		
Drawing Ref.	N/A	Enclosures : ☐ ☒ ☐ ☒ ☒ ☐ ☐ ☐ ☐ BOQ Pages Specification Pages Drawings Spec. Compliance Statement Trade License Cataloge/ Profile Test Reports Samples ISO Certificate (If Applicable) Previous Approvals	
Manufacturer	Envirocon Construction Products P.O. Box 28577, Abu Dhabi UAE		
Local Supplier	Envirocon Construction Products P.O. Box 28577, Abu Dhabi UAE 97125503473		
FOR CONTRACTOR	 04 May 2024  Date & Signature		
Name: Mohamed Zayed			
ENGINEER'S COMMENTS			
Material Engineer	Please refer attached comment sheet		
Name:	Date & Signature		
Additional Comments	Date & Signature		
RE Remarks:	 07/05/2024  Date & Signature		
Name : Ibrahim Saidi	STATUS : ☐ ☒ ☐ ☐ ☐ Approved Approved as Noted Revise & Re-submit Rejected For Information		

Project:	Construction of Enabling Works - Phase 2 of Reem Hills Development on Plot TMP2, Sector RT7, Al Reem Island, Abu Dhabi, UAE.
Ref. No.	RHP2P1-EW-NSC-XX-00-MT-ST-00017_00
Description:	Material Submittal for ECOGROUT PHT - Envirocon
Date:	7 May 2024

ENGINEER'S COMMENTS

Structural Comments:

Reviewed with Status - Code "B"

1. The proposed material use is a pile top fairing grout. Thickness and size limitations shall comply as per manufacturer's recommendation.
2. Method of use, mixing and placement shall comply as per manufacturer recommendation.
3. Sample cubes shall be collected and tested by the approved 3rd party laboratory to confirm its technical properties and compressive strength more than the pile concrete compressive strength.
4. All materials delivered on site shall be from the approved supplier and the same source mentioned in the submittal. Delivery notes to be attached along with MIRs.
5. Submit MIR for all materials delivered on site.
6. Application of material shall be as per required in contract documents.
7. Approval is subject to satisfactory performance of materials delivered on site.
8. All relevant licenses and certificates shall remain valid throughout the project duration.
9. Submit project related method statement of material application for approval.



Agripino Gerardo