



MATERIAL SUBMITTAL

Project:	BAPS Abu Dhabi Hindu Mandir, Abu Dhabi, UAE (Phase - 02)				
Contract No:	Ancillary Building , Phase - 02	Document Submittal No.	SPML-BAPS-STR-MAR-CV-124	Rev	1
Employer:	BAPS HINDU MANDIR		Date:	24-Jun-23	
Engineer:	Capital Engineering Consultancy LLC		Subject: Material Submittal for Epoxy Flooring works-Envirocon Construction products Factory LLC.		
Architect of Records (AOR):	Capital Engineering Consultancy LLC				
Contractor:	Shapoorji Pallonji Mideast LLC (SPML)				

Contractor	Items Description											
	✓	Material		Sample	Programme		Other					
		As Specified					Alternative					
	✓	Civil		Structural		Electrical		Irrigation		Fire & Fighting		Other
		Architectural		Landscape		HVAC		Plumbing		Fire Alarm		
		Area					Level					
	Element											
	Attachments											
		Sample		Brochure		Spec Comparison		Others				
	Supplier/Manufacture: M/s Quantum General Contracting LLC											

Description : Material Submittal for Epoxy Flooring works-Envirocon Construction products Factory LLC.

Contractor PM's Signature

Date : 24.06.23

RECEIVED

Date: 24/06/23

Time: 10:00 am

Engineer's Comments

* Subject is approval of
drawing, M.S. MAR.
* To comply with Evidence

Receipt
Acknowledged by
Engineer
Received By:
Date & Time

A-Approved
B-Approved As Noted
C-Revised & Resubmi
D-Rejected
E-Information

Reviewed By :

Project Director's Signature
Date:

Receipt Acknowledged by
SPML

Signature:

Received By:
Date & Time

RECEIVED
24 JUN 2023
Date: 27-OCT-
2020A12-Y52B25A13-Y52



Form Revision: B
2020A12-Y52B25A13-Y52

موسنادة Musnada		Dorch Gruppe DC Abu Dhabi		شركة المجموعة المتكاملة للمقاولات Combined Group Contracting Co.		
MATERIAL SUBMITTAL FORM						
Part A: Project & Record Information:						
Project Name	Design, Construction, Completion and Maintenance of Remaining Works of Zayed City Water Supply Main			MS.Ref.No	54830-00SIT-ZZ-CGC-CIN-MAT-0033	
Client	ADM	End User	TRANSCO	Rev.No	0.0	
Employer	Abu Dhabi General Services Company (Musnada)			Darwing Ref.	As Attached	
PMC	N/A			BOQ Ref: if any	As Attached	
Engineer	M/s. Dorch Gruppe DC, Abu Dhabi			Approx. Qty		
Contractor	Combined Group Contracting Emirates L.L.C.			Submission Date	22/12/2022	
Part B: Material Submittal Discipline:						
Related Discipline	☒ Civil Material ☐ Architectural Material ☐ Electrical Material ☐ Mechanical Material ☐ Others (Specify):					
Part C: Material Details				Attachment Checklist		
Spec's. Ref.	W-P-SS-005			1	Compliance checklist ☒	
Specified Material	Above Ground Concrete Protection (Epoxy Material with UV Resistant Polyurethane Topcoat)			2	Copy of the related specs ☒	
Proposed Material	Above Ground Concrete Protection (Epoxy Material with UV Resistant Polyurethane Topcoat)			3	Copy of the related drawings ☒	
	ECO HARD HBE 60, ECO HARD PU 100, ECO HARD EP PRIMER & ECO HARD EPFC			4	Copy of the related BOQ ☒	
Manufacturer's	Name	M/s. Envirocon Construction Products LLC		5	Copy of the related Standards ☒	
	Address	Abu Dhabi, UAE		6	Material Technical Data Sheet ☒	
Supplier's	Name	M/s. Envirocon Construction Products LLC		7	Previous test results ☒	
	Address	Abu Dhabi, UAE		8	Warranty ☒	
Estidama Approval	N/A			9	Musnada Previous Approvals ☒	
Justification of Alternative Material				10	Other Relevant Approvals ☒	
Part C: Contractors Review				11	License/s of Manufacturer ☒	
	M.E	HSE	QA/QC	Project Manager	12	ISO 9001 Certificate ☒
Name	Sajan	Raheel Ahamed	Alex Alfonsô	Eng. Tawfiq Adham	13	Sample with Sample Tag ☒
Signature					14	Estidama Compliance Approval ☒
Date	22/12/2022	22/12/2022	22/12/2022	22/12/2022	15	Others ☒
We do certify that the material submitted herewith has been reviewed in details and in accordance with the Contract Documents except as otherwise stated here above.						
Part D: Engineers Review / Approval						
Approved As Noted as per attached comment Sheet ref no.P126--MUS-RW-CS-0131-R0						
Employer/ Engineer Approval	☐ A - Approved ☐ C - Revised and resubmit ☒ B - Approved with comments ☐ D - Rejected					
Note(1): Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer.						
	Engineer's ME / SE		Engineer's RE		For Musnada	
Name	Eng. Mobashar Hussain		Eng. Shaji P.P		Eng. Sultan Omar Al Sheryani	
Signature						
Date	06/01/2023		06/01/2023			



 					
PROJECT: Design, Construction, Completion and Maintenance of Remaining Works of "Construction of Zayed City Water Supply Main" Contract No: PD/CA/BPS/HK/R6408/P126-2013-54830/22/39					
Comment Sheet Ref: P126-MUS-RW-CS-0131-R0		Date: 03.01.2023		DOCUMENT - COMMENT SHEET - RESPONSE SHEET	
Submittal Ref: 54830-00SIT-ZZ-CGC-CIN-MAT-0033-00		Date: 30.12.2022		SUBJECT: MAT Submittals for Above Ground Concrete Protection (ECHOHARD HBE 60, ECHOHARD PU 100, ECHOHARD EP PRIMER & ECHOHARD EPFC) M/s. Envirocon Construction Products LLC Abu Dhabi - UAE)	
Musanada/Dorsch Comments		M/s. Combined Group Response - R1	MUS/Dorsch Comment on Res-1 from M/s. Combined Group	M/s. Combined Group Response - R2	MUS/Dorsch Comment on Res-2 from M/s. Combined Group
1	The proposed Supplier M/s Envirocon is approved in the Contract Standard Vendor list, however currently the approval status is expired. During the construction phase, Contractor to submit the valid registration certificate.				
2	The coating sample shall be performed on-site for the Engineer's approval as a prerequisite to the final approval of the material.				
3	Installation shall be in strict compliance with the Manufacturer Method Statement and approved shop drawings.				
4	The method statement shall explain the method of checking the TDFT by the Engineer during the course of the works in addition to the pulling-off test.				
5	All consignment delivered to the site shall be accompanied with the Manufacturer's QC test reports / third party test report, warranty certificate, project delivery details etc.				
6	A duly filled material submittal form shall be provided. Please check and correct the Date on the submittal form.				
TRANSCO Comments - R0		M/s. Combined Group Response - R1	TRANSCO Comment on Res-1 from M/s. Combined Group	M/s. Combined Group Response - R2	TRANSCO Comment on Res-2 from M/s. Combined Group
1	The Material Data Sheet shall be filled with the material main physical and mechanical Properties. Such as but is not limited to the TDFT, colour, etc.				
Note: The above comments and/or approvals do not relieve the Contractor from his obligation in the Contract to ensure conformance to the specifications. Any specifications deviations found subsequent to approval are to be corrected by the Contractor to the satisfaction of the OWNER/ENGINEER.					

Status : Approved with Comments "B"

Signed: 
Dorsch



Signed: _____
MUSANADA

Signed: 
SHZ/OM
ADDG-TRANSCG

MATERIAL SUBMITTAL FORM

Part A: Project & Record Information:

Project Name	Design, Construction, Completion and Maintenance of Remaining Works of Zayed City Water Supply Main	MS.Ref.No	54830-00SIT-ZZ-CGC-CIN-MAT-0033
Client	ADM End User TRANSCO	Rev.No	0.0
Employer	Abu Dhabi General Services Company (Musandaa)	Darwing Ref.	As Attached
PMC	N/A	BOQ Ref: if any	As Attached
Engineer	M/s. Dorsch Gruppe DC, Abu Dhabi	Approx. Qty	
Contractor	Combined Group Contracting Emirates L.L.C.	Submission Date	22/12/2022

Part B: Material Submittal Discipline:

Related Discipline	☒ Civil Material	☐ Architectural Material	☐ Electrical Material
	☐ Mechanical Material	☐ Others (Specify):	

Part C: Material Details

Spec's. Ref.	Attachment Checklist
Specified Material	1 Compliance checklist ☒
Proposed Material	2 Copy of the related specs ☒
	3 Copy of the related drawings ☒
	4 Copy of the related BOQ ☒
	5 Copy of the related Standards ☒
Manufacturer's Name	6 Material Technical Data Sheet ☒
Manufacturer's Address	7 Previous test results ☒
Supplier's Name	8 Warranty ☒
Supplier's Address	9 Musandaa Previous Approvals ☒
Estidama Approval	10 Other Relevant Approvals ☒
Justification of Alternative Material	11 License/s of Manufacturer ☒
	12 ISO 9001 Certificate ☒

Part C: Contractors Review

	M.E	HSE	QA/QC	Project Manager
Name	Sajan	Raheel Ahamed	Alex Alfonsô	Eng. Tawfiq Adham
Signature				
Date	22/12/2022	22/12/2022	22/12/2022	22/12/2022

We do certify that the material submitted herewith has been reviewed in details and in accordance with the Contract Documents except as otherwise stated here above.

Part D: Engineers Review / Approval

Employer/ Engineer Approval	☐ A - Approved	☐ C - Revised and resubmit
	☐ B - Approved with comments	☐ D - Rejected

Note(1): Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer.

	Engineer's ME / SE	Engineer's RE	For Musandaa
Name	Eng. Mobashar Hussain	Eng. Shaji P.P	Eng. Sultan Omair Al Sheryani
Signature			
Date			



PROJECT NO.: 794

PROJECT NAME: PROPOSED WAREHOUSE & RUNWAY @ ABU DHABI

CLIENT :
CONSULTANT : E11 ENGINEERING CONSULTANCY & PROJECT MANAGEMENT
CONTRACTOR : ESNAD BUILDINGS CONTRACTING COMPANY

DATE : 14-May-19
Ref. NO. : AUH-104-MAT-087
SHEET :

MATERIAL SUBMITTAL

WE ARE FORWARDING HERewith ☐ UNDER SEPARATE COVER ☒ THE MATERIAL LISTED BELOW:-

THIS SUBMITTAL IS INTENDED FOR
(TICK AS APPROPRIATE)

☒ APPROVAL/COMMENT

☐ INFORMATION/RECORD

AS PER YOUR REQUEST

REF:

TYPE: ☐ SAMPLE

DESCRIPTION OF MATERIAL : Technical Submittal for Flooring Epoxy Paint (Ecohard EPFC)
SPECIFICATION OR CONTRACT DOCUMENT REFERENCE :
MANUFACTURER (NAME & ADDRESS) : Ms. Tashareek
SUPPLIER AND/OR LOCAL AGENT (CONTACT NUMBER) : Ms. Tashareek
AREA/LOCATION OF USE :
DESCRIPTION OF SAMPLE :
SPECIFICATION COMPARISON SHEET : N/A
COMPARISON IN CASE OF ALTERNATE SUBMITTAL : N/A
TECHNICAL DETAIL :

H.E. Sheikh Mansour Bin Zayed Al Nahyan ENGINEERING OFFICE		
EOM	Dept.	Responsible
Action:		
Info:		
Review:		
Project No:	11566	
DC Reg. No:		
DC Rep. Initials:		
Receiver's Initials:		
Dist. Date:		
Onward Distribution		

THE CONTRACTOR:
We certify that this submitted material is strictly complying with the Contract Documents except for the deviations specified in the attachments otherwise stated

CONTRACTOR:

SIGNATURE:

NAME: Mr. Khaled M. Al-Masri (Project Manager) DATE: 14 May 19

CONTRACTOR STAMP

RECEIVED BY: Client Rep.

SIGNATURE:
STAMP

DATE:

RECEIVED BY: CONSULTANT

SIGNATURE:
STAMP

DATE:

TO: CONTRACTOR

YOUR SUBMITTAL HAS BEEN REVIEWED AND GIVEN THE APPROVAL CATEGORY AS NOTED ABOVE:
FOR DETAILS OF OUR COMMENTS, REFER TO THE ATTACHED CONSULTANT COMMENTS.

TICK IF ATTACHED

CONSULTANT REMARKS:

Approved
1) Submit sample for colour approval
2) Installation to be as per manufacturer's recommendation

Correction or comments made relative to submittals during this review does not relieve the Contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general conformance with the information given in the contract documents. The Contractor is responsible for confirming and correlating all dimensions, selecting fabrication process and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

CONSULTANT
SIGNATURE: N.M. 21/5/19
STAMP:
DATE: 21/5/2019

RECEIVED BACK BY:

SIGNATURE:
STAMP:

DATE:

RECEIVED BACK BY: CONTRACTOR

CONTRACTOR:
STAMP:

DATE:

APPROVAL STATUS CODE:

A APPROVED

B APPROVED AS NOTED

C REVISE & RESUBMIT

D REJECTED

E NOTED FOR INFORMATION