

MATERIAL SUBMITTAL FORM

Part A: Project & Record Information:

Project Name	Design, Construction, Completion and Maintenance of Remaining Works of Zayed City Water Supply Main	MS.Ref.No	54830-00SIT-ZZ-CGC-CIN-MAT-0030
Client	ADM End User TRANSCO	Rev.No	0.0
Employer	Abu Dhabi General Services Company (Musandada)	Darwing Ref.	As Attached
PMC	N/A	BOQ Ref: if any	As Attached
Engineer	M/s. Dorsch Gruppe DC, Abu Dhabi	Approx. Qty	
Contractor	Combined Group Contracting Emirates L.L.C.	Submission Date	05/01/2023

Part B: Material Submittal Discipline:

Related Discipline	☒ Civil Material	☐ Architectural Material	☐ Electrical Material
	☐ Mechanical Material	☐ Others (Specify):	

Part C: Material Details

Spec's. Ref.	Attachment Checklist
W-P-SS-005	1 Compliance checklist ☒
Specified Material	2 Copy of the related specs ☒
	3 Copy of the related drawings ☒
Proposed Material	4 Copy of the related BOQ ☒
	5 Copy of the related Standards ☐
Manufacturer's Name	6 Material Technical Data Sheet ☒
Manufacturer's Address	7 Previous test results ☒
Supplier's Name	8 Warranty ☐
Supplier's Address	9 Musandada Previous Approvals ☒
Estdama Approval	10 Other Relevant Approvals ☒
Justification of Alternative Material	11 License/s of Manufacturer ☒
	12 ISO 9001 Certificate ☒

Part C: Contractors Review

	M.E	HSE	QA/QC	Project Manager	
Name	Sajan	Raheel Ahamed	Alex Alfonso	Eng. Tawfiq Adham	13 Sample with Sample Tag ☐
Signature					14 Estdama Compliance Approval ☐
Date	05/01/2023	05/01/2023	05/01/2023	05/01/2023	15 Others ☒

We do certify that the material submitted herewith has been reviewed in details and in accordance with the Contract Documents except as otherwise stated here above.

Part D: Engineers Review / Approval

Approved As Noted as per attached comment Sheet ref no.P126--MUS-RW-CS-0143-R0

Employer/ Engineer Approval	☐ A - Approved	☐ C - Revised and resubmit
	☒ B - Approved with comments	☐ D - Rejected

Note 1: Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer.

	Engineer's ME / SE	Engineer's RE	For Musandada
Name	Eng. Mobashar Hussain	Eng. Shaji P.P	Eng. Sultan Omar Al Sheryani
Signature			
Date	17/01/2023		

17/01/2023





MATERIAL SUBMITTAL

Project:	BAPS Abu Dhabi Hindu Mandir, Abu Dhabi, UAE (Phase - 02)				
Contract No:	Ancillary Building , Phase - 02	Document Submittal No.	SPML-BAPS-STR-MAR-CV-124	Rev	1
Employer:	BAPS HINDU MANDIR		Date:	24-Jun-23	
Engineer:	Capital Engineering Consultancy LLC		Subject: Material Submittal for Epoxy Flooring works-Envirocon Construction products Factory LLC.		
Architect of Records (AOR):	Capital Engineering Consultancy LLC				
Contractor:	Shapoorji Pallonji Mideast LLC (SPML)				

Contractor	Items Description										
	✓	Material		Sample	Programme		Other				
		As Specified			Alternative						
	✓	Civil		Structural		Electrical		Irrigation		Fire & Fighting	Other
		Architectural		Landscape		HVAC		Plumbing		Fire Alarm	
		Area				Level					
		Element									
		Attachments									
		Sample		Brochure		Spec Comparison		Others			
		Supplier/Manufacture: M/s Quantum General Contracting LLC									

Description : Material Submittal for Epoxy Flooring works-Envirocon Construction products Factory LLC.

Contractor PM's Signature

Date : 24.06.23

RECEIVED

Date: 24/06/23

Time: 10:00 am

Engineer's Comments

* Subject is approval of
drawing, M.S. MAR.
* To comply with Evidence

Receipt
Acknowledged by
Engineer
Received By:
Date & Time

A-Approved
B-Approved As Noted
C-Revised & Resubmi
D-Rejected
E-Information

Reviewed By :

Project Director's Signature
Date:

Receipt Acknowledged by
SPML

Signature:

Received By:
Date & Time

RECEIVED
24 JUN 2023
Date: 27-OCT-
2020A12:Y52B25A13:Y52



Form Revision: B
2020A12:Y52B25A13:Y52

MATERIAL SUBMITTAL FORM

Part A: Project & Record Information:

Project Name	Design, Construction, Completion and Maintenance of Remaining Works of Zayed City Water Supply Main	MS.Ref.No	54830-00SIT-ZZ-CGC-CIN-MAT-0033
Client	ADM End User TRANSCO	Rev.No	0.0
Employer	Abu Dhabi General Services Company (Musnada)	Darwing Ref.	As Attached
PMC	N/A	BOQ Ref: if any	As Attached
Engineer	M/s. Dorch Gruppe DC, Abu Dhabi	Approx. Qty	
Contractor	Combined Group Contracting Emirates L.L.C.	Submission Date	22/12/2022

Part B: Material Submittal Discipline:

Related Discipline	☒ Civil Material	☐ Architectural Material	☐ Electrical Material
	☐ Mechanical Material	☐ Others (Specify):	

Part C: Material Details

Spec's. Ref.	Attachment Checklist
W-P-SS-005	1 Compliance checklist ☒
Specified Material	2 Copy of the related specs ☒
	3 Copy of the related drawings ☒
Proposed Material	4 Copy of the related BOQ ☒
	5 Copy of the related Standards ☐
Manufacturer's Name	6 Material Technical Data Sheet ☒
Manufacturer's Address	7 Previous test results ☒
Supplier's Name	8 Warranty ☐
Supplier's Address	9 Musnada Previous Approvals ☒
Estidama Approval	10 Other Relevant Approvals ☒
Justification of Alternative Material	11 License/s of Manufacturer ☒
Part C: Contractors Review	12 ISO 9001 Certificate ☒
M.E.	13 Sample with Sample Tag ☐
HSE	14 Estidama Compliance Approval ☐
QA/QC	15 Others ☒
Project Manager	
Name	Sajan Raheel Ahamed Alex Alfonsõ Eng. Tawfiq Adham
Signature	
Date	22/12/2022 22/12/2022 22/12/2022 22/12/2022

We do certify that the material submitted herewith has been reviewed in details and in accordance with the Contract Documents except as otherwise stated here above.

Part D: Engineers Review / Approval

Approved As Noted as per attached comment Sheet ref no.P126--MUS-RW-CS-0131-R0

Employer/ Engineer Approval	☐ A - Approved	☐ C - Revised and resubmit
	☒ B - Approved with comments	☐ D - Rejected

Note(1): Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer.

Engineer's ME / SE	Engineer's RE	For Musnada
Name	Eng. Mobashar Hussain	Eng. Shaji P.P
Signature		
Date	06/01/2023	06/01/2023





مسانادة
musanaada



Dorsch Gruppe
D.C. Abu Dhabi



مسانادة
Musanaada Group & Construction P. Sc.

PROJECT: Design, Construction, Completion and Maintenance of Remaining Works of "Construction of Zayed City Water Supply Main"

Contract No: PD/CA/BPS/HK/R6408/P126-2013-54830/22/39

Comment Sheet Ref.: P126-MUS-RW-CS-0131-R0		DOCUMENT - COMMENT SHEET - RESPONSE SHEET	
Date: 03.01.2023		SUBJECT: MAT Submittals for Above Ground Concrete Protection (ECHOHARD HBE 60, ECHOHARD PU 100, ECHOHARD EP PRIMER & ECHOHARD EPFC) M/s. Envirocon Construction Products LLC Abu Dhabi - UAE)	
Submittal Ref.: 54830-00SIT-ZZ-CGC-CIN-MAT-0033-00		Date: 30.12.2022	
No.	Musanaada/Dorsch Comments	M/s. Combined Group Response - R1	MUS/Dorsch Comment on Res-1 from M/s. Combined Group
1	The proposed Supplier M/s Envirocon is approved in the Contract Standard Vendor list, however currently the approval status is expired. During the construction phase, Contractor to submit the valid registration certificate.		M/s. Combined Group Response - R2
2	The coating sample shall be performed on-site for the Engineer's approval as a prerequisite to the final approval of the material.		MUS/Dorsch Comment on Res-2 from M/s. Combined Group
3	Installation shall be in strict compliance with the Manufacturer Method Statement and approved shop drawings.		
4	The method statement shall explain the method of checking the TDFT by the Engineer during the course of the works in addition to the pulling-off test.		
5	All consignment delivered to the site shall be accompanied with the Manufacturer's QC test reports / third party test report, warranty certificate, project delivery details etc.		
6	A duly filled material submittal form shall be provided. Please check and correct the Date on the submittal form.		
	TRANSCO Comments - R0	M/s. Combined Group Response - R1	TRANSCO Comment on Res-1 from M/s. Combined Group
1	The Material Data Sheet shall be filled with the material main physical and mechanical Properties. Such as but is not limited to the TDFT, colour, etc.		M/s. Combined Group Response - R2
			TRANSCO Comment on Res-2 from M/s. Combined Group

Note: The above comments and/or approvals do not relieve the Contractor from his obligation in the Contract to ensure conformance to the specifications. Any specifications deviations found subsequent to approval are to be corrected by the Contractor to the satisfaction of the OWNER/ENGINEER.

Signed:  06/01/2023

Dorsch

Signed:  ADDG-TRANSCG

MUSANADA

Status : Approved with Comments "B"

MATERIAL SUBMITTAL FORM



Part A: Project & Record Information:

Project Name	Design, Construction, Completion and Maintenance of Remaining Works of Zayed City Water Supply Main	MS.Ref.No	54830-00SIT-ZZ-CGC-CIN-MAT-0033
Client	ADM End User TRANSCO	Rev.No	0.0
Employer	Abu Dhabi General Services Company (Musandaa)	Darwing Ref.	As Attached
PMC	N/A	BOQ Ref: if any	As Attached
Engineer	M/s. Dorsch Gruppe DC, Abu Dhabi	Approx. Qty	
Contractor	Combined Group Contracting Emirates L.L.C.	Submission Date	22/12/2022

Part B: Material Submittal Discipline:

Related Discipline	☒ Civil Material	☐ Architectural Material	☐ Electrical Material
	☐ Mechanical Material	☐ Others (Specify):	

Part C: Material Details

Spec's. Ref.		W-P-SS-005	Attachment Checklist				
Specified Material		Above Ground Concrete Protection (Epoxy Material with UV Resistant Polyurethane Topcoat)	1	Compliance checklist	✓		
			2	Copy of the related specs	✓		
			3	Copy of the related drawings	✓		
Proposed Material		Above Ground Concrete Protection (Epoxy Material with UV Resistant Polyurethane Topcoat) ECOHARD HBE 60, ECOHARD PU 100, ECOHARD EP PRIMER & ECOHARD EPFC	4	Copy of the related BOQ	✓		
			5	Copy of the related Standards			
Manufacturer's	Name	M/s.Envirocon Construction Products LLC	6	Material Technical Data Sheet	✓		
	Address	Abu Dhabi,UAE	7	Previous test results	✓		
Supplier's	Name	M/s.Envirocon Construction Products LLC	8	Warranty			
	Address	Abu Dhabi,UAE	9	Musanada Previous Approvals	✓		
Estidama Approval		N/A	10	Other Relevant Approvals	✓		
Justification of Alternative Material			11	License/s of Manufacturer	✓		
Part C: Contractors Review			12	ISO 9001 Certificate	✓		
	M.E	HSE	QA/QC	Project Manager	13	Sample with Sample Tag	
Name	Sajan	Raheel Ahamed	Alex Alfonsô	Eng. Tawfiq Adham	14	Estidama Compliance Approval	
Signature					15	Others	✓
Date	22/12/2022	22/12/2022	22/12/2022	22/12/2022			

We do certify that the material submitted herewith has been reviewed in details and in accordance with the Contract Documents except as otherwise stated here above.

Part D: Engineers Review / Approval

Employer/ Engineer Approval	☐ A - Approved	☐ C - Revised and resubmit
	☐ B - Approved with comments	☐ D - Rejected

Note(1): Employer's/ Engineer's approval is for conformance with information given and design concept expressed in Contract Documents. Approval does not authorize changes to Contract Documents. Employer's/ Engineer's approval does not relieve the Contractor from his contractual obligation to ensure conformance to all Contract Documents. Any deviations, to the Contract Documents found subsequent to Employer's/ Engineer's approval are to be corrected by the Contractor at no extra Cost/Time to the Employer.

	Engineer's ME / SE	Engineer's RE	For Musandaa
Name	Eng. Mobashar Hussain	Eng. Shaji P.P	Eng. Sultan Omair Al Sheryani
Signature			
Date			



ESNAD

PROJECT NO.: 794

PROJECT NAME: PROPOSED WAREHOUSE & RUNWAY @ ABU DHABI

CLIENT :
CONSULTANT : E11 ENGINEERING CONSULTANCY & PROJECT MANAGEMENT
CONTRACTOR : ESNAD BUILDINGS CONTRACTING COMPANY

DATE : 14-May-19
Ref. NO. : AUH-104-MAT-086
SHEET :

MATERIAL SUBMITTAL

WE ARE FORWARDING HERewith ☐ UNDER SEPARATE COVER ☒ THE MATERIAL LISTED BELOW:-

THIS SUBMITTAL IS INTENDED FOR (TICK AS APPROPRIATE)
☒ APPROVAL/COMMENT ☐ INFORMATION/RECORD ☐ AS PER YOUR REQUEST
REF:.....

TYPE: ☐ SAMPLE

DESCRIPTION OF MATERIAL : Technical Submittal for Flooring Epoxy Paint (Ecohard HBE 60)
SPECIFICATION OR CONTRACT DOCUMENT REFERENCE :
MANUFACTURER (NAME & ADDRESS) : Ms. Tashareek
SUPPLIER AND/OR LOCAL AGENT (CONTACT NUMBER) : Ms. Tashareek
AREA/LOCATION OF USE :
DESCRIPTION OF SAMPLE :
SPECIFICATION COMPARISON SHEET : N/A
COMPARISON IN CASE OF ALTERNATE SUBMITTAL : N/A
TECHNICAL DETAIL :

H.H. Sheikh Mansour Bin Zayed Al Nahyan ENGINEERING OFFICE		
EOM	Dept.	Responsible
Action:		
Info:		
Review:		
Project No:	11565	
DC Reg. No:		
DC Rep. Initials:		
Receiver's Initials:		
Dist. Date:		
Onward Distribution		

THE CONTRACTOR:
We certify that this submitted material is strictly complying with the Contract Documents except for the deviations specified in the attachments
otherwise stated.

CONTRACTOR:
SIGNATURE: 
NAME: Mr. Abdel Mustafa (Project Manager) DATE: 14 May 19

CONTRACTOR STAMP

RECEIVED BY: Client Rep.

SIGNATURE:
STAMP

DATE:

RECEIVED BY: CONSULTANT

SIGNATURE:
STAMP

DATE:

TO: CONTRACTOR


YOUR SUBMITTAL HAS BEEN REVIEWED AND GIVEN THE APPROVAL CATEGORY AS NOTED ABOVE:
FOR DETAILS OF OUR COMMENTS, REFER TO THE ATTACHED CONSULTANT COMMENTS:

TICK IF ATTACHED

CONSULTANT REMARKS:

Approved
Submit sample for approval
Installation to be as per manufacturers recommendation

Correction or comments made relative to submittals during this review does not relieve the Contractor from compliance with the requirements of the drawings and specifications. This check is only for review of general conformance with the design concept of the project and general conformance with the information given in the contract documents. The Contractor is responsible for confirming and correlating all dimensions, selecting fabrication process and techniques of construction, coordinating his work with that of other trades, and performing his work in a safe and satisfactory manner.

CONSULTANT
SIGNATURE: 
STAMP:

DATE: 21/5/19

SIGNATURE:
STAMP:

DATE:

RECEIVED BACK BY:

RECEIVED BACK BY: CONTRACTOR

CONTRACTOR:
STAMP:

DATE:

APPROVAL STATUS CODE:

A APPROVED

B APPROVED AS NOTED

C REVISE & RESUBMIT

D REJECTED

E NOTED FOR INFORMATION

Material Submittal

Reference No.: TG2080-MTS-CVL-GN-0019

Rev. 01

Date:

9/Sep/2022

Project :

TG2080 - Qasr Al Sarab Private Villa-Phase-3

Employer:

M/s. Trojan Construction Group

Consultant / Engineer:

M/s EHAF Consulting Engineers

Main Contractor :

M/s. Trojan General Contracting LLC

Sub-Contractor :

M/s Desert Man Transporting & Contracting LLC

Description

Material Submittal for Ecohard HBE 60 Solvent Free Epoxy for Rip Rap.
Manufacturer: M/s. Envirocon Construction Products Abu Dhabi UAE
Supplier: M/s Envirocon Construction Products Abu Dhabi UAE

AL SARAB VILLA				
DATE:	/	/	20	
Designation	Action	Follow up	Info	Sup
Resident Engineer				
Sr. Architect / IO				
Sr. Civil Engineer				
Sr. MEP Engineer				
File				

Sub-Contractor (Name and Ref.No)	Discipline	Area of Application	Specification Reference
M/s Desert Man Transporting & Contracting LLC	General	Ecohard HBE 60 Solvent Free Epoxy for Rip Rap Storm Water V-Ditch - Dune Villa	N/A

☐ Sample

☐ Technical Data

☐ Material Safety Data Sheet

☐ Test Certificate

☐ Warranty

☐ Previous Approvals

☐ Compliance

☐ Method Statement

Manufacturer:

M/s Envirocon Construction Products

Country of Origin: Abu Dhabi UAE

Tel: 02-5516505

Fax: 02-5516506

Email:

michael.edward@desertmangt.com

Local Agent:

DESERT MAN TRANSPORTING & CONTRACTING

P.O.Box No. 105972, Mussafah M-17

Abu Dhabi - U.A.E

Tel: 02-5516505

Fax: 02-5516506

Email:

michael.edward@desertmangt.com

Main Contractor (PM)

Name: Hussein Fadloon

Signature

Date: 9-Sep-2022

Name:

Signature

Date:

Received By Consultant

Others

Soft Copy

+ Hard copy

Comments (Engineer/ Consultant)

A P P r o v e d A P P l i c a t i o n c e r t i f i c a t e t o b e s u b m i t t e d
d u r a b i l i t y / w a r r a n t y T e m p l a t e t o b e g i v e n f o r
C o n f i r m i n g d u r a b i l i t y
i t h a s b e e n c o n v e y e d t h a t B r o w n c o l o u r t o b e u s e d

☐ A. Approved

☒ B. Approved with Comments

☐ C. Revise and Resubmit

☐ D. Rejected

Name:

Moh'd Talafta

Signature

Date:

Comments (Client/ Employer)

demonstrate mock
submit Method statement

Subjective Approval

☐ A. Approved

☐ B. Approved with Comments

☐ C. Revise and Resubmit

☐ D. Rejected

Name:

Signature

Date:

Received by Contractor