

ALDAR PROPERTIES PJSC QUALITY MATERIAL SUBMITTAL

للمشاريع
PROJECTS

PROJECT:	Construct Only Contract (With Contractor's Designed Portion) For Mohamed Bin Zayed, Sector Z29 – Infrastructure and Streetscape Works, United Arab Emirates		
CLIENT:	M/s ALDAR PROJECTS	Date:	27/08/2023
PMC:	N/A	Doc. Ref.:	
CONSULTANT:	M/s DAR AL-HANDASAH CONSULTANT	MS No.:	MBZ29-IN-WBG-ZZ-WT-XX-MT-PW-00447
CONTRACTOR:	M/s. Western Baidoonah Group for General Contracting LLC.	REV No.:	P03
REFERENCE NO:	'MBZ29-IN-WBG-ZZ-WT-XX-MT-PW-00447		

DESCRIPTION OF MATERIAL (One item per Submittal):

TRADE:	M/s Envirocon Construction Products Factory L.L.C, Abu Dhabi, U.A.E	SAMPLE
DESCRIPTION:	External Epoxy Coating System (Ecohard EPFC+Ecohard EP Primer + Ecohard HBE60+Ecohard PU100) & Internal Epoxy Coating System (Ecohard EPFC+Ecohard EP Primer+ Ecohard HBE60) For Potable Water Chambers and Structure Work (Alternative Supplier)	☐ YES ☒ NO

• Attach all relevant technical literature marked to identify relevant descriptions, current test certificate, samples, draft warranty Certificate.....etc.

• Attach a certificate stating compliance with Contract requirements, with specification comparison sheet.

• Highlight any element of contractual non-compliance in this submittal. ☒ As per Specification ☐ Alternative Material

REFERENCES		REASON FOR ALTERNATIVE
Drawing Ref. No.:	Z29-02-00001-03-11-WA-DAR-DG-000504 Z29-02-00001-03-11-WA-DAR-DG-000507 Z29-02-00001-03-11-WA-DAR-DG-000508	
Specification Ref.:	ADWEA/ADDC Standard Specification for Civil Works , Specification for Concrete Works , W-C-SS-05 Rev-02 , Clause : 10.10.6 Above Ground Concrete Protection	
BOQ Ref. No.:	Infrastructure and Streetscape Works for MBZ-29, Part 6-1: Water Supply System, Class K: Pipe Works - Manholes and Pipe Work Ancillaries (Manholes), Page 6 of 10 Item Ref: A to k & Page 7 of 10 Item Ref: D to G	
International Standards Ref:	N/A	
MANUFACTURER NAME:	Envirocon Construction Products Factory L.L.C, Abu Dhabi, U.A.E	
SUPPLIER NAME:	Envirocon Construction Products Factory L.L.C, Abu Dhabi, U.A.E	
PROGRAMME:	As per the Site Requirements	
Date Required on Site:	As per the Site Requirements	
Expected Date of Arrival on Site:	As per the Site Requirements	

PMC/CONSULTANT's COMMENTS

Code:- B Refer to the following comments:

1. This approval shall not relieve the contractor from his obligation under the contract to conform with relevant specifications, standard, authority approval requirements.
2. Prepare mockup sample of proposed Coating System for testing and checking compliance by the Independent Testing Agency
3. Any damaged Coating on site shall be 100% replaced as per Specification Requirements during the entire duration of the Warranty Period.
4. Materials delivered to site shall be submitted for Dar review along with Manufacturer's delivery note, Test Reports and Certificate of Origin.
5. Samples at random shall be collected from delivered material and tested for adhesion at Approved Testing Laboratory in presence of Dar.
6. Storage, Handling and Installation shall be as per Contract Specifications, Authority Specifications, Contract Drawings, approved shop drawings and Manufacturer's written instructions.
7. Area of application shall be as per approved shop drawings, Contract Drawings and Specifications.
8. Quality Control shall be as per ADWEA/ADDC Specification 10.10.2 to 10.10.6 and 10.10.7, C-W-SS-005, Specifications for Concrete. Test results shall be recorded by approved Testing Laboratory and submitted for Dar approval and future records as per ADDC requirements.
9. Final approval subject to ADDC approval and satisfactory taking over by Client or the Authorities having

Consultant Representative	Signature:	Date	Stamp	
Name: Damien Hughes Sr. Resident Engineer		18/10/2023		☐ Code A ☐ Code D
Client Representative	Signature:	Date	☒ Code B ☐ Code C	☐ Code E
Name:				

NOTE: Permission to proceed on behalf of PMC/Consultant does not constitute acceptance or approval by PMC/Consultant of design, calculations, analysis, tests, and methods of materials developed or selected by the Contractor and does not relieve him from compliance with his contractual obligations.