

NORR**TECHNICAL SUBMITTAL**

Project Name: LIV Marina Tower - 2

Subtl. #: LIV2-CRCC-MT-ST-0040.

Rev. : 00

TO : NORR Architects and Engineers

P.O. Box 13213, Dubai, U.A.E

FROM : China Railway 18th Bureau Group LLC**Contract Title :** LIV Marina Tower - 2 (Main Works)**Date Submitted :** 27-Apr-2023**Time :** 04:06 PM**Specification / BOQ Ref. :****Location of use :** Zone : Level: Projectwide Gridline :**ENCLOSURES :****ISSUED FOR :**

- | | | | |
|--|--|---|--|
| ☒ Technical Data | ☒ Test Reports | ☐ O&M Manual (Prel.) | ☐ Schedule |
| ☐ Samples | ☐ Calculations | ☐ O&M Manual (Final) | ☒ Others |
| ☒ Compliance Statement | ☐ Warranty | ☐ Preliminary As-Built | |
| ☒ Method Statement | ☐ Shop Drawing | ☐ Final As-Built | |

- ☒ Issued For Approval
- ☐ Issued For Information / Records

DESCRIPTION :

MATERIAL SUBMITTAL FOR **ECOPATCH LS** - REPAIR OVERHEAD UP TO 50MM THK, REPAIR WALL UP TO 75MM THK FOR COLUMNS ABOVE 36 FLOOR & ALL FLOOR SLABS (ALTERNATE SUPPLIER)

MANUFACTURER :**SUPPLIER :**

ENVIROCON CONSTRUCTION PRODUCTS
FACTORY LLC

ENVIROCON CONSTRUCTION PRODUCTS
FACTORY LLC

Only One Item per Submittal is recommended

CONFIRMATION OF CONTRACTOR'S Q.C. DEPARTMENT

Confirmation of Co-ordination & compliance with Specifications, Contract drawings, Method Statements and QAQC Plan.

Tick Box ☒ YES ☐ NO

Note: If NO, a departure from Specifications, approved drawings, Method Statement and Quality Control Plan to be recorded and attached.

Contractor :

Date : 27-Apr-2023

ENGINEERS COMMENTS :**ISSUE / RECEIVE STAMPS**

Conditional approval subject to the following conditions:

- Pre-mix concrete material shall be use for of structural vertical/overhead element identified, agreed and approved by the engineer.
- Contractor shall submit a brief Method Statement of concrete repair (pre-mix pack); surface preparation, mixing, application. curing, etc. for the engineer's review and approval.
- Contractor shall submit concrete repair material compressive strength test report result at 7 and 28 days for the engineer's review and approval.
- Contractor shall submit MIR (Material Inspection Request) in every concrete repair material (pre-mix pack) delivery at site.

For and on behalf of The Engineer:

Date: 10 May 2023

STATUS :

The Engineers comments shall not relieve the Contractor of any of his responsibilities under the Contract.

- ☐ A - Reviewed
- ☒ B - Reviewed as Noted
- ☐ C - Revise & Resubmit
- ☐ R - Not Reviewed

Received for Contractor :