

SUB CONTRACTORS APPROVAL FORM

Project Name: Commercial Building for Mr. Ahmed Rashed Al Murar File No. ADCE 923
 Location: Sector E-11, Plot C-23, Abu Dhabi, UAE
 Consultant: Heberger Engineering Consultancy Ref No. 923-PQ-023-R00
 Contractor: Hashim Contracting & Gen. Maintenance Co. LLC Date 10-May-23

Type of Work: **Repair Material**

Sub Contractor Name: **Envirocon**

Company Profile Contents:


☒ Prequalification

☒ Valid Trade License

☒ Organization Chart

☒ Previous Approvals

CONTRACTOR : HASHIM CONTRACTING & GEN. MAINTENANCE CO. LLC


 No Objection Subject to Incorporation
 of All Comments as Noted



Originator of the submittal/ Eng: Samer Ataallah Al Ali

Mob. No: 0559966852

Contractor Authorized signature:

Date: 10-May-23

CONSULTANT COMMENTS:

Please refer comments on the attached comments sheet

19-06-2023


 Heberger Engineering
 مبرج للهندسة

Approval Status:

☐ A: Approved

☒ B: Approved as noted

☐ C: Revise & Resubmit

☐ D: Not Approved

Reviewer of the submittal/ Eng :

Mob. No:

Consultant Authorized signature:

Date:

ADCE (Abu Dhabi Commercial Engineering) Received

☐ A: Approved

☐ B: Approved as noted

☐ C: Revise & Resubmit

☐ D: Not Approved

Date: _____

All the supportive documents must be presented and filed at project site.

* (Approval does not relieve the Contractor from his contractual obligations and responsibilities)

COMMENTS SHEET

PROJECT: Commercial Building for Mr. Ahmed Rashed Al Murar, Sector E-11, Plot C-23, Abu Dhabi, UAE			
Consultant: 	Client: 	Main Contractor: 	
PRE-QUALIFICATION SUBMITTAL		File No. ADCE 923	
		Transmittal Ref:	
		Rev No.	
		Date:	
Subject:			
☐ A. No Objection ☒ B. No Objection Subject to incorporation of all comments as noted ☐ C. Rejected to be resubmitted ☐ D. Rejected			
The attached Pre-qualification of M/s ENVIROCON is approved subjected to as follows: 1) The repair material is not allowed to use for all structural repair cases unless the contractor should submit the specific use of repair material along with detailed shop drawings and method statement for the required repair. 2) Repair material to be used strictly as per the manufacturer's recommendation 3) The contractor should submit the requirement of the structural repair prior to commencement work on site. 4) The contractor is responsible to maintain the quality of work as per the project specs, standard procedures and authorities regulations.			
		 Heberger Engineering مبرج للهندسة	
Consultant Confirmation :		Date:	